




John Quinlan - Sales Representative - Cell 845-240-0882

ABOVE GROUND PROPANE TANK SPECIFICATIONS


WATER GALLON CAPACITY	LEG SPACING	DIAMETER	LENGTH	HEIGHT WITH HOOD	WEIGHT
1990	192"	46"	23' 11"	4' 7"	3400 LBS
1450	139.5"	46"	17' 4"	4' 7"	2658 LBS
1000	121"	41"	16' 0"	4' 2"	1760 LBS
850	86"	41"	13' 9"	4' 2"	1440 LBS
500	60"	37"	9' 11"	3' 10"	949 LBS
325	60"	30"	9' 11"	3' 3"	597 LBS
250	60"	30"	7' 10"	3' 3"	483 LBS
150	60"	24"	7' 0"	2' 9"	314 LBS
120	45.25"	24"	5' 8"	2' 9"	257 LBS



Trench for gas line to be 24" deep. 6" of sand above and below the gas line must be provided for protection of the gas line.

UNDERGROUND PROPANE TANK SPECIFICATIONS

WATER GALLON CAPACITY	LEG SPACING	DIAMETER	LENGTH	HEIGHT WITH HOOD	WEIGHT
1990	192"	46"	23' 11"	5' 11"	3400 LBS
1450	139.5"	46"	17' 4"	5' 11"	2658 LBS
1000	121"	41"	16' 0"	5' 6"	1760 LBS
850	86"	41"	13' 9"	5' 6"	1440 LBS
500	60"	37"	9' 11"	5' 2"	949 LBS
325	60"	30"	9' 11"	4' 7"	597 LBS
250	60"	30"	7' 10"	4' 7"	483 LBS
150	60"	24"	5' 8"	4' 11"	314 LBS
120	45.25"	24"	5' 9"	4' 11"	257 LBS



The tank should be buried leaving 10" above grade. 6" of sand below & on all sides for protection of the tank.

Gas lines should be buried to a depth of 18" with 6" of sand below and above for protection of the gas line.